# Terminator<sup>™</sup> DE-B Beacon LED End of Circuit Light Kit INSTALLATION PROCEDURES





The Heat Tracing Specialists®

### Terminator™ DE-B Beacon

#### Receiving, Storing and Handling . . .

- 1. Inspect materials for damage incurred during shipping.
- 2. Report damages to the carrier for settlement.
- 3. Identify parts against the packing list to ensure the proper type and quantity has been received.
- 4. Store in a dry location.

#### Kit Contents . . .



Item	Quantity	Description
1	1	Expediter Assembly Grommet Compressor Grommet Support Base with O-Ring
2	1	Light Module Cover
3	1	Banding Guide
4	1	Banding (fits 10" pipe and below)
5	1	LED Light Module

#### Order Separately . . .

#### **SCTK Connection Termination Kits (per cable)**

SCTK-1D for BSX, RSX, VSX SCTK-2D for KSX, HTSX SCTK-3D for FP, HPT
















#### Dimensions . . .



#### **Installation Precautions...**

- To minimize the potential for arcing and fire caused by product damage or improper installation use ground-fault protection. The National Electrical Code (NEC) and Canadian Electrical Code (CEC) require ground-fault protection of equipment for each branch circuit supplying electric heat tracing.
- Installation must comply with Thermon requirements and be installed in accordance with the NEC, CEC, or any other applicable national and local codes.
- Component approvals and performance ratings are based on the use of Thermon specified parts only. User supplied power connection fittings must be listed or certified for intended use.
- De-energize all power sources before opening enclosure.
- Keep ends of heating cable and kit components dry before and during installation.
- Individuals installing these products are responsible for complying with all applicable safety and health guidelines. Proper personal protective equipment, or PPE, should be utilized during installation. Contact Thermon if you have any additional questions.

#### Certifications/Approvals . . .



IP66/Type 4X  $-60^{\circ}$ C  $\leq$  Ta  $\leq$  +45 $^{\circ}$ C



Ordinary & Hazardous Locations Class I, Division 2, Groups A, B, C, & D, Zone 2 IIC T6


Class II, Division 2, Groups F & G, Class III

#### Tools Required . . .







## **Terminator™ DE-B Beacon**




 Locate bus connection (HPT and FP only) and cable as shown. Cut end of cable at angle to aid in piercing grommet. Leave additional cable for expansion loop.



2. Insert cable into expediter. If mounted on bottom of pipe, punch out weep hole.




**3.** Slide expediter toward pipe and route cable through support base entry.




**4.** Insert banding guide into expediter and snap into place.




**5.** Mount expediter to pipe using pipe band. Do not band over cable.




**6.** Cut off end of cable.




7. Terminate cable with appropriate SCTK termination kit. Refer to SCTK installation instructions. Push excess cable back through expediter. Tape cable expansion loop to pipe.



 Connect bus wires using small wire nuts (for BSX, HTSX and KSX) or medium wire nuts (for RSX, VSX, HPT and FP). See wiring schematic for connections.




Wiring Schematic for LED Light



**9.** Slide the light module cover over light module.



**10.** Engage threads. Rotate light module cover clockwise and tighten cap securely. Make sure latch mechanism is in the locked position.



**11.** To remove cap, lift latch mechanism, as shown and unscrew cap. De-energize all power sources before opening enclosure.

